



## **LPG – Propane:**

An operational permit is required to store, transport on site, dispense, use, or handle hazardous materials, such as Liquid Propane Gas (LPG) in amounts greater than 5.6 gallons (23.67 lbs.), but less than 125 gallons (527.5 lbs.).

Conditions of this permit are as follows:

- All containers shall be marked.
- LP-Gas cylinders cannot be located in close proximity to the means of egress from a building or tent.
- LP-Gas cylinders shall be adequately protected to prevent tampering, damage by vehicles, or other hazards.
- Portable LP-Gas containers shall be securely fastened in place to prevent unauthorized movement.
- Portable fire extinguishers are required:
  - At least one 40 BC fire extinguisher shall be available within 50 feet of the gas cylinder.
  - A Class K extinguisher shall be provided if cooking.
- No Smoking signs shall be posted. No smoking is permitted within 25 feet of LP-Gas cylinders.
- Standby personnel may be required at the discretion of the fire code official.

During the application process be prepared to upload the following documents:

1. Photo or copy of the fire extinguisher tag. If cooking, you must also have a Class K extinguisher and provide a photo or copy of the tag for the Class K extinguisher.
2. A detailed site map with legend must be provided showing the entire event area, location of set up on the property, including the location of equipment and tank(s), street intersections, landmarks, and buildings in close proximity to tanks(s).